



Petition #:	2017-085	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	May 8, 2017
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via existing 8-inch water distribution mains located along Robs Road and Merrie Rose Avenue. There is also system availability via an existing 12-inch water distribution main along Caldwell Road.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer mains located along Merrie Rose Avenue and Caldwell Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.