



<b>Petition #:</b>	2017-086	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	May 8, 2017
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along General Industrial Road, an existing 6-inch water distribution main located along Highlake Drive, and an existing 2-inch water distribution main located along Americana Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located within the rezoning boundary, along Americana Avenue, and Eastway Drive. There is also available 8-inch gravity sewer mains located along Highlake Drive and Lakecrest Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.