



To: Tammie Keplinger, CMPC  
From: Ashley Botkin, Engineering Land Development  
Date: May 30, 2017  
Rezoning Petition #: 2017-091

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

**Comments for this rezoning:**

Tom Ferguson (Engineering) – Show Potential 35' Post Construction Stormwater Ordinance stream buffer, including buffer zones or provide documentation as specified in the Ordinance that no perennial or intermittent stream exists on the site. Relocate proposed improvements outside stream buffer or obtain approval from City Stormwater Administrator for any proposed buffer encroachment.

Peter Grisewood (Urban Forestry) – Site must comply with Tree Ordinance

Jay Wilson (Erosion Control) – stream/wetland survey required