

Charlotte Fire Department Comments fo

Petitions: 2017-095 thru 110
Hearing Month: 20-Jul-17
Reviewed By: S SULLIVAN
Review Date: 12-Jul-17

| <u>Petition Number:</u> | <u>Petitioners Name:</u> |
|--------------------------------|---------------------------------|
| 2017-095 | Lincoln Harris, LLC |
| 2017-096 | Cambridge-Eastfield, LLC |
| 2017-097 | Charlotte Douglas International |
| 2017-098 | Urban Investments |
| 2017-099 | Fenton Place LLC |
| 2017-100 | LAXMI Hotels Group, Inc |
| 2017-101 | Optimist Park Partners, LLC |
| 2017-102 | David Weekly Homes |
| 2017-103 | Asana Partners, LP |
| 2017-104 | Cambridge Properties, Inc |
| 2017-105 | Rexford Office Holdings, LLC |
| 2017-106 | Charlotte Rescue Mission |
| 2017-107 | The Carroll Companies |
| 2017-108 | Arden Group, LLC |
| 2017-109 | Enviro-Master International Fra |
| 2017-110 | Lincoln Harris, LLC |

or Rezoning Petitions

Comments:

No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.

No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.

No comments

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No comments

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No comments

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.