

Charlotte Fire Department Comments fo

Petitions: 2017-095 thru 110
Hearing Month: 20-Jul-17
Reviewed By: S SULLIVAN
Review Date: 12-Jul-17

<u>Petition Number:</u>	<u>Petitioners Name:</u>
2017-095	Lincoln Harris, LLC
2017-096	Cambridge-Eastfield, LLC
2017-097	Charlotte Douglas International
2017-098	Urban Investments
2017-099	Fenton Place LLC
2017-100	LAXMI Hotels Group, Inc
2017-101	Optimist Park Partners, LLC
2017-102	David Weekly Homes
2017-103	Asana Partners, LP
2017-104	Cambridge Properties, Inc
2017-105	Rexford Office Holdings, LLC
2017-106	Charlotte Rescue Mission
2017-107	The Carroll Companies
2017-108	Arden Group, LLC
2017-109	Enviro-Master International Fra
2017-110	Lincoln Harris, LLC

or Rezoning Petitions

Comments:

No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.

No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.

No comments

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No comments

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No comments

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.

No on street parking on roads less than 26 feet clear width. See charlottefire.org for other requirements.