



| | | | |
|-----------------------------|---------------|-----------------------|-------------------------------|
| Petition #: | 2017-109 | Review Number: | 1 |
| Petition Respondent: | Keri Cantrell | Date Reviewed: | 7/24/2017 |
| Phone Number: | 704-391-5141 | Email Address: | keri.cantrell@charlottenc.gov |

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located along Nations Ford Road and an existing 8-inch water distribution main located along Tyvola Road.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along Nations Ford Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.