



Petition #:	2017-110	Review Number:	1
Petition Respondent:	Keri Cantrell	Date Reviewed:	7/24/2017
Phone Number:	704-391-5141	Email Address:	keri.cantrell@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along Fairview Road.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along Fairview Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.