



Petition #:	2017-112	Review Number:	1
Petition Respondent:	Keri Cantrell	Date Reviewed:	8/16/2017
Phone Number:	704-391-5141	Email Address:	keri.cantrell@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via existing 16-inch water transition mains located along South Tryon Street and Youngblood Road. There is also water availability via an existing 8-inch water distribution main located along Birnamwood Lane.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located Youngblood Road and through parcels 219-11-101 and 21911-130. There is also an existing gravity sewer main located through parcel 219-11-115.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.