

## Charlotte Fire Department Comments fo

**Petitions:** 2017-111 THRU 126  
**Hearing Month:** 17-Aug-17  
**Reviewed By:** S SULLIVAN  
**Review Date:** 10-Aug-17

<b><u>Petition Number:</u></b>	<b><u>Petitioners Name:</u></b>
2017-111	Lincoln Harris, LLC
2017-112	Sweetgrass Residential Partner:
2017-113	Kolter Homes, LLC
2017-114	Bainbridge Companies
2017-115	CapRock, LLC
2017-116	JKS Management 1600 Montfoi
2017-117	Profile Homes
2017-118	Phillips Investment Properties,
2017-119	Brinker Properties, LLC
2017-120	Flywheel Group
2017-121	Flywheel Group
2017-122	Victory Christian Center Inc
2017-123	Harris Teeter, LLC
2017-124	Stockbridge 77 Corporate Park,
2017-125	Eastgroup Properties, L.P.
2017-126	Corp of Latter-Day Saints

## or Rezoning Petitions

### Comments:

NO COMMENTS

No on street parking on roads less than 26' clear width. See [Charlottefire.org](http://Charlottefire.org) for other requirements.

No on street parking on roads less than 26' clear width. See [Charlottefire.org](http://Charlottefire.org) for other requirements.

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

NO COMMENTS

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.

NO COMMENTS

NO COMMENTS

NO COMMENTS

No on street parking on roads less than 26 feet clear width. See [charlottefire.org](http://charlottefire.org) for other requirements.