

Job Name	Acela Number	Notes
CRAIG SMITH	2017-127	NO COMMENTS
METROPOLITAN REALTY COMPANY LLC	2017-128	NO COMMENTS
DURBAN DEVELOPMENT, LLC	2017-129	PROVIDE APPROVED CFD TURNAROUND 20 FEET UNOBSTRUCTED WIDTH. TURN RADIUS 30 FEET INSIDE AND 42 FEET OUTSIDE
TWENTYNINE FIFTEEN OPERATIONS, LLC	2017-130	NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS
SAUSSY BURBANK, LLC	2017-131	PROVIDE ACCESS ROAD WITHIN 150 FEET OF MOST REMOTE EXTERIOR WALL
MATTAMY HOMES (ATT: BOB WIGGINS)	2017-132	NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS
MATTAMY HOMES (ATTN: BOB WIGGINS)	2017-133	NO ON STREET PARKING ON ROADS LESS THAT 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS
813 BELMONT LLC	2017-134	NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS
REDWOOD USA	2017-135	NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS
MATTHEW GOGGIN	2017-136	NO COMMENTS
JEMSITE DEVELOPMENT (ATT: JEFF FLATTERY)	2017-137	NO COMMENTS
AGS HOTELS NC, LLC	2017-138	NO COMMENTS
CITY SALVAGE INC	2017-139	AISLES AND PASSAGWAYS SHALL BE PROVIDED TO PERMIT REASONABLE ACCESS FOR FIRE FIGHTING OPERATIONS
MIDWOOD-OVERLOOK, LLC	2017-140	CFD ACCESS ROAD SHALL BE WITHIN 150 FEET OF MOST REMOTE EXTERIOR WALL OF STRUCTURE.
BEACON PROPERTIES	2017-141	NO COMMENTS