



Petition #:	2017-128	Review Number:	1
Petition Respondent:	Keri Cantrell	Date Reviewed:	9/15/2017
Phone Number:	704-391-5141	Email Address:	keri.cantrell@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system infrastructure accessible for the rezoning boundary via existing 12-inch, 6-inch, and 8-inch water distribution mains located along South Kings Drive. The water system is also accessible via an existing 6-inch water distribution main located along Charlottetowne Avenue.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along South Kings Drive and Charlottetowne Avenue.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-5801 for further information on reserving capacity up to 12-months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.