

| Job Name | Acela Number | Notes |
|------------------------------------------|--------------|------------------------------------------------------------------------------------------------------------|
| CRAIG SMITH | 2017-127 | NO COMMENTS |
| METROPOLITAN REALTY COMPANY LLC | 2017-128 | NO COMMENTS |
| DURBAN DEVELOPMENT, LLC | 2017-129 | PROVIDE APPROVED CFD TURNAROUND 20 FEET UNOBSTRUCTED WIDTH. TURN RADIUS 30 FEET INSIDE AND 42 FEET OUTSIDE |
| TWENTYNINE FIFTEEN OPERATIONS, LLC | 2017-130 | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS |
| SAUSSY BURBANK, LLC | 2017-131 | PROVIDE ACCESS ROAD WITHIN 150 FEET OF MOST REMOTE EXTERIOR WALL |
| MATTAMY HOMES (ATT: BOB WIGGINS) | 2017-132 | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS |
| MATTAMY HOMES (ATTN: BOB WIGGINS) | 2017-133 | NO ON STREET PARKING ON ROADS LESS THAT 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS |
| 813 BELMONT LLC | 2017-134 | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS |
| REDWOOD USA | 2017-135 | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS |
| MATTHEW GOGGIN | 2017-136 | NO COMMENTS |
| JEMSITE DEVELOPMENT (ATT: JEFF FLATTERY) | 2017-137 | NO COMMENTS |
| AGS HOTELS NC, LLC | 2017-138 | NO COMMENTS |
| CITY SALVAGE INC | 2017-139 | AISLES AND PASSAGWAYS SHALL BE PROVIDED TO PERMIT REASONABLE ACCESS FOR FIRE FIGHTING OPERATIONS |
| MIDWOOD-OVERLOOK, LLC | 2017-140 | CFD ACCESS ROAD SHALL BE WITHIN 150 FEET OF MOST REMOTE EXTERIOR WALL OF STRUCTURE. |
| BEACON PROPERTIES | 2017-141 | NO COMMENTS |