

| Job Name                                 | Acela Number | Notes  |
|--|--------------|--|
| CRAIG SMITH                              | 2017-127     | NO COMMENTS  |
| METROPOLITAN REALTY COMPANY LLC          | 2017-128     | NO COMMENTS  |
| DURBAN DEVELOPMENT, LLC                  | 2017-129     | PROVIDE APPROVED CFD TURNAROUND 20 FEET UNOBSTRUCTED WIDTH. TURN RADIUS 30 FEET INSIDE AND 42 FEET OUTSIDE |
| TWENTYNINE FIFTEEN OPERATIONS, LLC       | 2017-130     | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS  |
| SAUSSY BURBANK, LLC                      | 2017-131     | PROVIDE ACCESS ROAD WITHIN 150 FEET OF MOST REMOTE EXTERIOR WALL   |
| MATTAMY HOMES (ATT: BOB WIGGINS)         | 2017-132     | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS  |
| MATTAMY HOMES (ATTN: BOB WIGGINS)        | 2017-133     | NO ON STREET PARKING ON ROADS LESS THAT 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS  |
| 813 BELMONT LLC                          | 2017-134     | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS  |
| REDWOOD USA                              | 2017-135     | NO ON STREET PARKING ON ROADS LESS THAN 26 FEET CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS  |
| MATTHEW GOGGIN                           | 2017-136     | NO COMMENTS  |
| JEMSITE DEVELOPMENT (ATT: JEFF FLATTERY) | 2017-137     | NO COMMENTS  |
| AGS HOTELS NC, LLC                       | 2017-138     | NO COMMENTS  |
| CITY SALVAGE INC                         | 2017-139     | AISLES AND PASSAGWAYS SHALL BE PROVIDED TO PERMIT REASONABLE ACCESS FOR FIRE FIGHTING OPERATIONS           |
| MIDWOOD-OVERLOOK, LLC                    | 2017-140     | CFD ACCESS ROAD SHALL BE WITHIN 150 FEET OF MOST REMOTE EXTERIOR WALL OF STRUCTURE.                        |
| BEACON PROPERTIES                        | 2017-141     | NO COMMENTS  |