

Job Name	Acela Number	Luesa Number
JUDSON STRINGFELLOW	2017-142	No Comments
JDSI, LLC	2017-143	No Comments
DOUBLE L INVESTMENTS OF CHARLOTTE, LLP	2017-144	No Comments
MATTAMY HOMES (Attn: Bob Wiggins)	2017-145	No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements
North State Development, LLC (Attn:Shane Seagle)	2017-146	No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements
QUICK TRIP CORP (JUDY ALLIE)	2017-147	No Comments
Eastgroup Properties, L.P. (John Coleman)	2017-148	No comments
ABW CHARLOTTE, LLC	2017-149	No comments
MATTAMY HOMES (ATTN: BOB WIGGINS)	2017-150	No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements
The Housing Partnership (Attn: Julie Porter)	2017-151	No Comments
LOCKARD DEVELOPMENT, INC	2017-152	No Comments
JDSI, LLC	2017-153	No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements
JASON BRAGA-ICON RESIDENTAL	2017-154	No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements. Dead end access that exceeds 150' requires an approved CFD turnaround measuring 30' inside and 42' outside.
SCOUTS,LLC (BEN SEEGARS)	2017-155	DEAD END ACCESS THAT EXCEEDS 150' REQUIRES AN APPROVED CFD TURNAROUND MEASURING 30' INSIDE AND 42' OUTSIDE.
MARK MILLER	2017-156	Maintain 150' unobstructed access to nonsprinkled bldgs. 200' unobstructed access to sprinkled bldgs.
ESSEX HOMES SOUTHEAST, INC	2017-157	No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements
ROMAN GARCIA	2017-158	No Comments