



To: Tammie Keplinger, CMPC
From: Ashley Botkin, Engineering Land Development
Date: November 1, 2017
Rezoning Petition #: 2017-158

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson (Engineering) – No comments. (No rezoning plan received for review.)

Peter Grisewood (Urban Forestry) – Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. 15% of 1.58 acres = 0.237 acres tree save. Show tree save area on site map in common open space. Tree save must contain existing healthy tree canopy. Tree save must be 30' width minimum.

Jay Wilson (Erosion Control) – No requirements