

Acela Number	Luesa Number
2017-159	No on street parking. 150 feet access required to all exterior walls
2017-160	No on street parking. 150 feet access required to all exterior walls. See charlottefire.org for other requirements.
2017-161	No comments
2017-162	No on street parking on Wickford Plc or W Worthington Ave
2017-163	No on street parking
2017-164	No comments
2017-165	No comments
2017-166	No comments
2017-167	No on street parking on Bamboo St
2017-168	150 ft access required to all exterior walls. No on street parking. See charlottefire.org for other requirements
2017-169	No comments
2017-170	No on street parking on Euclid Ave
2017-171	No on street parking. See charlottefire.org for other requirements.
2017-172	No on street parking on Harrill St or Belmont Ave
2017-173	No on street parking on Doggett St or Hawkins St
2017-174	No comments