



Petition #:	2017-165	Review Number:	1
Petition Respondent:	Keri Cantrell	Date Reviewed:	11/20/2017
Phone Number:	704-391-5141	Email Address:	keri.cantrell@charlottenc.gov

Comments:

Charlotte Water has accessible water system infrastructure for the rezoning boundary via an existing 16-inch water transmission main located along Northlake Mall Drive.

Charlotte Water has sanitary sewer system infrastructure accessible for the rezoning boundary via existing 8-inch gravity sewer mains located along Northlake Centre Parkway.

Development is encouraged to contact Installation Development Services (IDS) at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Will need to acquire Capacity Assurance prior to granting a service tap request; project will need to submit plans for private water permitting to IDS; development will need to contact CLTWater's New Services Group for meter information; and development will need to contact NC-DEQ Mooresville Regional Office (704) 663-1699 for information and procedures regarding sanitary sewer permitting.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-5801 for further information on reserving capacity up to 12 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.