

Acela Number	Luesa Number
2017-175	No on street parking. See charlottefire.org for other requirements
2017-176	No on street parking. See charlottefire.org for other requirements
2017-177	No on street parking. See charlottefire.org for other requirements
2017-178	No comments
2017-179	No on street parking. Dead end access exceeding 150 feet requires approved CFD turnaround. See charlottefire.org for other requirements
2017-180	No on street parking. See charlottefire.org for other requirements
2017-181	No on street parking. Dead end access exceeding 150 feet requires approved CFD turnaround. See charlottefire.org for other requirements
2017-182	No comments
2017-183	No on street parking. See charlottefire.org for other requirements
2017-184	No on street parking. Dead end access exceeding 150 feet requires approved CFD turnaround. See charlottefire.org for other requirements
2017-185	No on street parking. See charlottefire.org for other requirements
2017-186	No on street parking. See charlottefire.org for other requirements
2017-187	No on street parking. Dead end access exceeding 150 feet requires approved CFD turnaround. See charlottefire.org for other requirements
2017-188	Maintain unobstructed/unrestricted CFD access to structures. No on street parking. See charlottefire.org for other requirements.
2017-189	No comments
2017-190	No on street parking. See charlottefire.org for other requirements