



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFICE: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Tammie Keplinger, CMPC

From: Doug Lozner

Date of Review: December 18, 2017

Rezoning Petition #: 17-189

Existing Zoning: R-3

Proposed Zoning: I-1 (CD)

Location of Property: Approximately 42.6 acres located at the end of Horton Road, east of Garrison Road and west of I-485.

Recommendations Concerning Storm Water: The plan sheet indicates only a 30-ft Post Construction Buffer running along the eastern side of the property. Please include the 35-ft Post Construction Buffer section between the 30-ft and 50-ft buffer sections.