



| | | | |
|-----------------------------|---------------|-----------------------|-------------------------------|
| Petition #: | 2017-199 | Review Number: | 1 |
| Petition Respondent: | Keri Cantrell | Date Reviewed: | 1/23/2018 |
| Phone Number: | 704-391-5141 | Email Address: | keri.cantrell@charlottenc.gov |

Comments:

Charlotte Water has accessible water system infrastructure for the rezoning boundary.

Charlotte Water has sanitary sewer system infrastructure accessible for the rezoning boundary.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Already an Approved Charlotte Water project. Contact Charlotte Water with any changes or additions to the site plans.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-5801 for further information on reserving capacity up to 12 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.