



Petition #:	2017-202	Review Number:	1
Petition Respondent:	Keri Cantrell	Date Reviewed:	1/23/2018
Phone Number:	704-391-5141	Email Address:	keri.cantrell@charlottenc.gov

Comments:

Charlotte Water has accessible water system infrastructure for the rezoning boundary via existing 8-inch water distribution main located along Providence Church Lane.

Charlotte Water has sanitary sewer system infrastructure accessible for the rezoning boundary via existing 8-inch gravity sewer mains located along Providence Road and Providence Church Lane.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Submit application to the Capacity Assurance Program. Contact our New Services Group for water/sewer meters. Will have to go through our Donated Project Sections for a water/sewer extension if public road (if applicable). Will need to send plans for private water permitting (if applicable), and send plans to NC-DEQ Mooresville Regional Office (704) 663-1699 for sewer permitting (if applicable). Will need to provide Charlotte Water with a profile of the existing water main around any improvements or new driveway connections along Providence Church Lane.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-5801 for further information on reserving capacity up to 12 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.