



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFICE: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Tammie Keplinger, CMPC

From: Doug Lozner

Date of Review: February 15, 2018

Rezoning Petition #: 18-13

Existing Zoning: INST (CD)

Proposed Zoning: RE-1 (CD)

Location of Property: Approximately 6.27 acres located on the east side of Penninger Circle, south of Mallard Creek Rd.

Recommendations

Concerning Storm Water: Flooding and surface water quality impacts associated with impervious surfaces on this site are being addressed through compliance with the Post-Construction Stormwater Ordinance. Compliance may include installing devices that hold and slowly release runoff over time to reduce flooding potential, devices that filter pollutants from runoff before release to streams, preservation of vegetated stream buffer zones, preservation of upland trees and forested areas, or paying a mitigation fee in-lieu-of onsite stormwater control devices. Compliance with the Post-Construction Stormwater Ordinance addresses concerns related to flooding and surface water impacts and therefore staff has no further comments.