

Acela Number	Luesa Number
2018-016	NO COMMENTS
2018-017	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-018	No on street parking
2018-019	NO COMMENTS
2018-020	NO COMMENTS
2018-021	NO COMMENTS
2018-022	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-023	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-024	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-025	NO COMMENTS
2018-026	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-027	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-028	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-029	No on street parking if unable to maintain 20 ft unobstructed access at all times for CFD
2018-030	NO COMMENTS
2018-031	NO COMMENTS