



To: Tammie Keplinger, CMPC  
From: Ashley Botkin, Engineering Land Development  
Date: March 16, 2018  
Rezoning Petition #: 2018-025

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

**Comments for this rezoning:**

Tom Ferguson (Engineering) – Please add the following note under the ENVIRONMENTAL FEATURES heading: *Development or disturbance within the PCSO or SWIM Stream Buffers shall be coordinated with and subject to approval by Charlotte-Mecklenburg Storm Water Services and mitigated if required by City ordinance.*

Peter Grisewood (Urban Forestry) – Site must comply with the Tree Ordinance

Jay Wilson (Erosion Control) – Wetland determination and jurisdictional stream survey required. Area lies within the LLW Protected Area watershed overlay district and is subject to requirements of the

Critical Watershed Checklist. Recommend that protections similar to River District Rezoning be required here also, notably: 1. Appoint a qualified EC/WQ manager dedicated solely to the protection of surface waters during site construction; 2. Commitment to sizing basins to hold the 2-yr storm for 5 days and the 25 yr storm for 3 days while safely routing the 50 yr storm through the spillway; and 3. Providing larger stream buffers than required and a minimum 50' buffer around any wetland areas