

	Acela Number	Luesa Number
	2018-032	Maintain 20 feet unobstructed access road width at all times for CFD access.
	2018-033	No on street parking on road less than 26 feet clear width.
	2018-034	No comments
	2018-035	No on street parking on roads less than 26' clear width. See charlottefire.org for other requirements.
	2018-036	No on street parking on roads less than 26' clear width. See charlottefire.org for other requirements.
	2018-037	No on street parking on roads less than 26' clear width. See charlottefire.org for other requirements.
	2018-038	No comments
	2018-039	No on street parking
	2018-040	No comments
	2018-041	No on street parking on roads less than 26' clear width. See charlottefire.org for other requirements.
	2018-042	No comments
	2018-043	No comments
	2018-044	No on street parking on roads less than 26' clear width. See charlottefire.org for other requirements.
	2018-045	Access road shall be all weather surface capable of supporting 80,000 pound. Dead end access that exceeds 150' requires an approved CFD
		turnaround measuring 32' inside and 40' outside. Maintain 20' width unobstructed access road at all times for CFD.
	2018-046	No on street parking
	2018-047	No comments