



Charlotte Storm Water  
600 East Fourth Street  
Charlotte, N C 28202-2844  
OFFC: 704 . 336 . RAIN  
FAX: 704 . 336 . 6586

# Rezoning Petition Review

---

**To:** Tammie Keplinger, CMPC

**From:** Doug Lozner

**Date of Review:** April 20, 2018 (*Revised June 15, 2018*)

**Rezoning Petition #:** 18-44

**Existing Zoning:** R-3

**Proposed Zoning:** UR-2 (CD)

**Location of Property:** Approximately 7.5 acres located on the west side of Elm Ln and south of Camfield St.

## Recommendations

**Concerning Storm Water:** The proposed rezoning plan sheet indicates a proposed location for storm water management. Please include the following notes on the plan sheet under "Environmental Features":

- *The location, size, and type of storm water management systems depicted on the Rezoning Plan are subject to review and approval as part of the full development plan submittal and are not implicitly approved with this rezoning. Adjustments may be necessary in order to accommodate actual storm water treatment requirements and natural site discharge points.*
- *For adjoining parcels receiving stormwater discharge from the proposed BMP/Water Quality feature, the petitioner shall analyze the adequacy of the existing stormwater conveyance on the adjoining parcels. If the existing stormwater conveyance on the adjoining parcels is found to be inadequate, the Petitioner shall make a good faith effort with the property owner(s) to improve the stormwater conveyance or mitigate the stormwater discharge onto the adjoining parcels.*

## Recommendations

### Due to revisions:

*No additional recommendations are needed at this time.*