

Revised Rezoning June 2018 comments by Pete Grisewood, Urban Forestry

2017-050 No comments

2017-112 – Show tree save area and tree save calculations on site plan. Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. 15% of 28 acres = 4.2 acres tree save. Tree save must contain existing healthy tree canopy. No future ROW allowed in tree save area. Tree save must be 30' width minimum.

2017-180 No comments

2018-014 - Show tree save area and tree save calculations on site plan. Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. 15% of 18.95 acres = 2.84 acres tree save. Tree save must contain existing healthy tree canopy. Tree save must be 30' width minimum.

2018-028 – No comments

2018-029 – No comments

2018-043 – No comments

2018-044 - Show tree save area and tree save calculations on site map. Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. 15% of 7.5 acres = 1.125 acres tree save. Tree save must contain existing healthy tree canopy. Tree save must be 30' width minimum.

2018-048 – No comments

2018-049 – No comments

2018-050 – No comments

2018-052 – No comments

2018-056 - Show tree save area and tree save calculations on site map. Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. 15% of 9.3 acres = 1.395 acres tree save. Tree save must contain existing healthy tree canopy. Tree save must be 30' width minimum.

2018-057 – No comments

2018-060 – No comments

2018-061 – No comments

2018-062 – No comments