

Rezoning Transportation Analysis

Petition Number: 2018-064

General Location Identifier: 04721124

From: Felix Obregon, PE
fobregon@charlottenc.gov
704-432-5729

Reviewer: Rick Grochoske
rgrochoske@charlottenc.gov
704-432-1556

Revision Log:

Date	Description
07-23-2018	First Review
09-30-2018	Second Review

General Review Information

The site is at the signalized intersection of W WT Harris Boulevard (Class 2 major thoroughfare) & University Research Park Drive (local). Located in a corridor outside Route 4, the site is within the limits of the University City Area Plan.

CDOT's review of this rezoning petition is intended to ensure consistency with the Transportation Action Plan (TAP) which seeks to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

The site is located at the signalized intersection of W.T. Harris Boulevard and University Executive Park Drive. The developer is providing a 12' wide multi-use path along W.T. Harris Boulevard. The site plans commits to providing funding for pedestrian improvements at W.T. Harris Blvd and University Research Drive.

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Drive-In Bank	8,390 sf	1,240	Tax Record
Entitlement with Current Zoning	Drive-In Bank	8,390 sf	1,240	Tax Record
Proposed Zoning	Fast Food w/ Drive Thru	6,500 sf	3,230	Site Plan: 04-20-18
	Fast Food w/ Drive Thru	5,500 sf	2,730	Site Plan: 09-27-18

Outstanding Issues

~~Strikeout~~ = Not an outstanding issue

Rezoning Transportation Analysis

Petition Number: 2018-064

General Location Identifier: 04721124

- ~~1. **Curbline** The proposed zoning district has a setback measured from back of the existing or proposed future curbline. The location of the future back of curb on both WT Harris Blvd., and University Executive Park Dr. can remain as is.~~
- ~~2. **Traffic Study** A Traffic Impact Study/Transportation Technical Memorandum is not necessary for the complete review of this petition.~~
- ~~3. The petitioner should revise the site plan and conditional note(s) to provide a 12' multi-use path along the site's WT Harris Blvd. frontage.~~
- ~~4. The petitioner should revise the site plan and conditional note(s) committing to enter into a Developer's Traffic Signal Modification Agreement at WT Harris and University Executive Park Dr. This agreement will specify traffic signal and intersection modifications, including accessible ramps on both sides of WT Harris Blvd. University Executive Park Dr., a WT Harris pedestrian refuge island (i.e.: "Z" pedestrian crossing), pedestrian count-down signals on three (3) corners of the subject intersection, and a two phase pedestrian crossing to provide a safe pedestrian crossing of WT Harris Blvd. The petitioner should be responsible for the design and implementation of all the intersection pedestrian geometric improvements as part of their site work, including a monetary contribution towards the pedestrian/left turn signalization modifications.~~
- ~~5. The petitioner should revise the site plan to add a note specifying dedication and fee simple conveyance of all rights of way to the City before the site's first building certificate of occupancy is issued. CDOT requests right of way set at 2' behind back of sidewalk where feasible.~~
6. The petitioner should revise the site plan to add a note specifying all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes.

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business

Rezoning Transportation Analysis

Petition Number: 2018-064

General Location Identifier: 04721124

association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.