

Acela Number	Luesa Number
2018-064	No comments
2018-065	Provide approved CFD turnaround minimum width 20' with turning radius 30' inside 42' outside
2018-066	No comments
2018-067	No parking on street less than 26' clear width. Dead end access exceeding 150' requires an approved turnaround minimum width 20' with turning radius 30' inside 42' outside. See charlottefire.org for other requirements
2018-068	No comments
2018-069	No parking on street less than 26' clear width. Dead end access exceeding 150' requires an approved turnaround minimum width 20' with turning radius 30' inside 42' outside. See charlottefire.org for other requirements
2018-070	No comments
2018-071	No on street parking on road less than 26' clear width
2018-072	Dead end access exceeding 150' requires an approved turnaround minimum width 20' with turning radius 30' inside 42' outside. See charlottefire.org for other requirements
2018-073	No comments
2018-074	Fire hydrant shall be within 750' of most remote point of building as truck travels. Dead end access exceeding 150' requires an approved turnaround minimum width 20'with turning radius 30' inside 42' outside. See charlottefire.org for other requirements
2018-075	Fire hydrant shall be within 750' of most remote point of building as truck travels. Access road shall be within 200' of sprinklered building. See charlottefire.org for other requirements
2018-076	Fire hydrant shall be within 750' of most remote point of each building as truck travels.
2018-077	Fire hydrant shall be within 750' of most remote point of each building as truck travels.
2018-078	No parking on street less than 26' clear width
2018-079	Fire hydrant shall be within 750' of most remote point of building as truck travels. No parking on street less than 26' clear width