

| Acela Number | Luesa Number |
|--------------|---|
| 2018-080 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. No on |
| 2018-081 | No on street parking on road less than 26' clear width. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. See charlottefire.org for other requirements |
| 2018-082 | No comments |
| 2018-083 | No comments |
| 2018-084 | No on street parking on road less than 26' clear width. Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum |
| 2018-085 | No on street parking on road less than 26' clear width. Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-086 | No on street parking on road less than 26' clear width. Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-087 | No on street parking. Fire hydrant shall be within 750 of most remote point of building as fire truck travels. |
| 2018-088 | Fire hydrant shall be within 750 of most remote point of building as fire truck travels. Access road shall be within 150' of non-sprinklered bldg; 200' of sprinklered bldg. |
| 2018-089 | Fire hydrant shall be within 750 of most remote point of building as fire truck travels. No on street parking. |
| 2018-090 | Fire hydrant shall be within 750 of most remote point of building as fire truck travels. Access road shall be within 150' of non-sprinklered bldg; 200' of sprinklered bldg |
| 2018-091 | Fire hydrant shall be within 750 of most remote point of building as fire truck travels. No on street parking. |
| 2018-092 | Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. See charlottefire.org for other requirements |
| 2018-093 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' v |
| 2018-094 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. No on |
| 2018-095 | No comments |