

Acela Number	Luesa Number
2018-080	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. No on
2018-081	No on street parking on road less than 26' clear width. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. See charlottefire.org for other requirements
2018-082	No comments
2018-083	No comments
2018-084	No on street parking on road less than 26' clear width. Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum
2018-085	No on street parking on road less than 26' clear width. Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-086	No on street parking on road less than 26' clear width. Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-087	No on street parking. Fire hydrant shall be within 750 of most remote point of building as fire truck travels.
2018-088	Fire hydrant shall be within 750 of most remote point of building as fire truck travels. Access road shall be within 150' of non-sprinklered bldg; 200' of sprinklered bldg.
2018-089	Fire hydrant shall be within 750 of most remote point of building as fire truck travels. No on street parking.
2018-090	Fire hydrant shall be within 750 of most remote point of building as fire truck travels. Access road shall be within 150' of non-sprinklered bldg; 200' of sprinklered bldg
2018-091	Fire hydrant shall be within 750 of most remote point of building as fire truck travels. No on street parking.
2018-092	Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. See charlottefire.org for other requirements
2018-093	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' v
2018-094	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside. No on
2018-095	No comments