

Acela Number	Luesa Number
2018-096	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-097	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-098	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-099	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No parking on road less than 26' clear width. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius.
2018-100	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-101	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. See charlottefire.org for other requirements
2018-102	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-103	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-104	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside
2018-105	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-106	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.
2018-107	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width.
2018-108	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. Gated access shall comply with section D103.5 of IFC 2012. Fire hydrant required
2018-109	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Fire hydrant required to be within 750' from most remote point of building as fire truck travels. See charlottefire.org for other requirements
2018-110	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements.
2018-111	Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width.
2018-112	Fire hydrant required to be within 750' from most remote point of building as fire truck travels.