

| Acela Number | Luesa Number |
|--------------|--|
| 2018-096 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-097 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-098 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-099 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No parking on road less than 26' clear width. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius. |
| 2018-100 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-101 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. See charlottefire.org for other requirements |
| 2018-102 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-103 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements. |
| 2018-104 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Dead end fire apparatus access exceeding 150' requires approved turnaround minimum width 20' with turn radius 30' inside 42' outside |
| 2018-105 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-106 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |
| 2018-107 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. |
| 2018-108 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. Gated access shall comply with section D103.5 of IFC 2012. Fire hydrant required |
| 2018-109 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. Fire hydrant required to be within 750' from most remote point of building as fire truck travels. See charlottefire.org for other requirements |
| 2018-110 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. See charlottefire.org for other requirements. |
| 2018-111 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. No on street parking on road less than 26' clear width. |
| 2018-112 | Fire hydrant required to be within 750' from most remote point of building as fire truck travels. |