

2018_10_October Revised Rezoning Comments by Pete Grisewood

2016-112 – Add note: Site must comply with the Tree Ordinance.

2017-206 - Site must comply with the Tree Ordinance.

2018-067 - Site must comply with the Tree Ordinance.

2018-069 - Site must comply with the Tree Ordinance. On sheet RZ-2 change note VII. 3. to read “15%” tree save area.

2018-072 - Site must comply with the Tree Ordinance. Show tree save calculations on site map.

2018-088 – Add note: Site must comply with the Tree Ordinance.

2018-093 – Replanted tree save area is not permitted. Tree save must contain existing healthy tree canopy. Show tree save area and tree save calculations on site map. Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. $15\% \text{ of } 1.43 \text{ acres} = 0.21 \text{ acres tree save}$. Tree save must be 30' width minimum.

2018-097 - Site must comply with the Tree Ordinance.

2018-099 – Site must comply with the Tree Ordinance.

2018-103 – Site must comply with the Tree Ordinance.

2018-104 – Site must comply with the Tree Ordinance.

2018-105 – Site must comply with the Tree Ordinance.

2018-106 – Site must comply with the Tree Ordinance.

2018-108 – Site must comply with the Tree Ordinance.

2018-109 – Site must comply with the Tree Ordinance.

2018-110 – Add note: Site must comply with the Tree Ordinance.

2018-112 – Site must comply with the Tree Ordinance.