



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFC: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Tammie Keplinger, CMPC

From: Doug Lozner

Date of Review: September 21, 2018

Rezoning Petition #: 18-110

Existing Zoning: R-3

Proposed Zoning: R-8 (CD)

Location of Property: Approximately 38.4 acres located on the east side of Shopton Rd West, north of S Tryon St.

Site Plan Submitted: Yes

Recommendations Concerning Storm Water: Please label all stream buffers delineated on the rezoning plan as *"Potential 30-ft Post Construction Stormwater Ordinance Buffer."*

Please include the following note under *Environmental Features*:
"Development within the PCSO Buffer shall be coordinated with Charlotte-Mecklenburg Stormwater Services and mitigated if required by City ordinance."