

Acela Number	Luesa Number
2018-113	No Comments
2018-114	No Comments
2018-115	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.
2018-116	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.
2018-117	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.
2018-118	Access road shall be within 150' of non sprinkled buildings. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-119	No Comments
2018-120	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum
2018-121	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.
2018-122	No Comments
2018-123	No Comments
2018-124	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-125	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.