

| Acela Number | Luesa Number  |
|--------------|---|
| 2018-113     | No Comments   |
| 2018-114     | No Comments   |
| 2018-115     | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.      |
| 2018-116     | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.      |
| 2018-117     | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.      |
| 2018-118     | Access road shall be within 150' of non sprinkled buildings. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-119     | No Comments   |
| 2018-120     | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum   |
| 2018-121     | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less that 26' clear width.      |
| 2018-122     | No Comments   |
| 2018-123     | No Comments   |
| 2018-124     | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.  |
| 2018-125     | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.  |