



Charlotte Storm Water  
600 East Fourth Street  
Charlotte, N C 28202-2844  
OFFC: 704 . 336 . RAIN  
FAX: 704 . 336 . 6586

## Rezoning Petition Review

---

**To:** Tammie Keplinger, CMPC

**From:** Doug Lozner

**Date of Review:** October 22, 2018

**Rezoning Petition #:** 18-117

**Existing Zoning:** R-8 and MUDD (CD)

**Proposed Zoning:** UR-2 (CD)

**Location of Property:** Approximately 1.7 acres located on the northeast corner of the intersection of E Peterson Drive and S Tryon Street.

**Site Plan Submitted:** Yes

**Recommendations Concerning Storm Water:** Please revise note "2" under "Environmental Features" to read as follows: *"The petitioner shall comply with the Charlotte City Council approved and adopted Post Construction Stormwater Ordinance."*

Please remove references to the "Proposed SDE" and "Proposed culvert" on sheet RZ-2.

Charlotte-Mecklenburg Storm Water Services has permanent storm drainage easements (SDE) on a couple of the parcels for this rezoning request and appear to be shown on rezoning site plan sheet RZ-1. These easements can be found in map book 25526 pages 633-636 and map book 25526 pages 641-644. No buildings or structures are permitted over and across these easements. Please show the existing SDE limits on rezoning site plan sheet RZ-2 and adjust the site plan as necessary to meet the easement language agreements and requirements.

The rezoning site plan proposes encroachments into the Post Construction Stormwater Ordinance stream buffer. Any increase of impervious area within such buffer may not be allowed and is not approved with the rezoning process. Please include the following note under Environmental Features: *"Development within the SWIM/PCSO Buffer shall be coordinated with and subject to approval by Charlotte-Mecklenburg Storm Water Services and mitigated if required by City ordinance."*