



|                             |               |                       |                               |
|-----------------------------|---------------|-----------------------|-------------------------------|
| <b>Petition #:</b>          | 2018-131      | <b>Review Number:</b> | 1                             |
| <b>Petition Respondent:</b> | Bhavana Sinha | <b>Date Reviewed:</b> | 11/16/2018                    |
| <b>Phone Number:</b>        | 704-336-4976  | <b>Email Address:</b> | bhavana.sinha@charlottenc.gov |

**Comments:**

Summary: Water is accessible for this site. The proposed rezoning is located in an area that Charlotte Water has determined to have limited sanitary sewer system capacity. Sanitary sewer service will be dependent on the completion of a public infrastructure project—Charlotte Water’s Park Avenue & Wilmore Drive to I-77 Sanitary Sewer Project. This project was identified to support current and future customers, and any proposed sanitary sewer flow shall be coordinated to discharge after completion of said project. There is an anticipated completion date of late-2019.

Charlotte Water has accessible water system infrastructure for the rezoning boundary via an existing 6-inch water distribution main located along Winona Street and an 8-inch water distribution main located along South Mint Street.

The proposed rezoning is located in an area that Charlotte Water has determined to have limited sanitary sewer system capacity. Sanitary sewer service will be dependent on the completion of a public infrastructure project— Charlotte Water’s Park Avenue & Wilmore Drive to I-77 Sanitary Sewer Project. This project was identified to support current and future customers, and any proposed sanitary sewer flow shall be coordinated to discharge after completion of said project. There is an anticipated completion date of late-2019. It is recommended that the applicant contact the Charlotte Water New Services at (704) 432-2854 for further information and to discuss options regarding sanitary sewer system capacity.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Submit application to the Capacity Assurance Program. Contact our New Services Department for water/sewer services.

Reservation of sanitary sewer system capacity through the Charlotte Water’s Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-2854 for further information on reserving capacity up to 24 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.