

Acela Number	Luesa Number
2018-137	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-138	no comments
2018-139	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-140	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. Access shall comply with Section D107 of IFC 2012.
2018-141	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width.
2018-142	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. Access shall comply with Sections D106 and D107 of IFC 2012
2018-143	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. Access shall comply with Sections D106 of IFC 2012
2018-144	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width.
2018-145	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width.
2018-146	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-147	20 ft unobstructed clearance on street required at all times for CFD. See charlottefire.org for other requirements.
2018-148	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-149	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. See charlottefire.org for other requirements,
2018-150	20 ft unobstructed clearance on street required at all times for CFD. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-151	20 ft unobstructed clearance on street required at all times for CFD. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-152	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.