

| Acela Number | Luesa Number |
|--------------|---|
| 2018-137 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-138 | no comments |
| 2018-139 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-140 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. Access shall comply with Section D107 of IFC 2012. |
| 2018-141 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. |
| 2018-142 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. Access shall comply with Sections D106 and D107 of IFC 2012 |
| 2018-143 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. Access shall comply with Sections D106 of IFC 2012 |
| 2018-144 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. |
| 2018-145 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. |
| 2018-146 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-147 | 20 ft unobstructed clearance on street required at all times for CFD. See charlottefire.org for other requirements. |
| 2018-148 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-149 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. See charlottefire.org for other requirements, |
| 2018-150 | 20 ft unobstructed clearance on street required at all times for CFD. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-151 | 20 ft unobstructed clearance on street required at all times for CFD. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-152 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |