

Acela Number	Luesa Number
2018-153	no comments
2018-154	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-155	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside.
2018-156	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-157	Incomplete submittal
2018-158	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width.
2018-159	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels.
2018-160	No parking on road less than 26'clear width. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. See charlottefire.org for other requirements.
2018-161	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width.
2018-162	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. See charlottefire.org for other requirements.
2018-163	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD.
2018-164	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Nonsprinklered building requires access road within 150' of most remote point of building; 200' of sprinklered building
2018-165	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD.
2018-166	Incomplete submittal
2018-167	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD.
2018-168	Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width.
	20' unobstructed clearance on street required at all times for CFD.