

| Acela Number | Luesa Number |
|--------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2018-153 | no comments |
| 2018-154 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-155 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. |
| 2018-156 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-157 | Incomplete submittal |
| 2018-158 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. |
| 2018-159 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. |
| 2018-160 | No parking on road less than 26'clear width. Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. See charlottefire.org for other requirements. |
| 2018-161 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. |
| 2018-162 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. See charlottefire.org for other requirements. |
| 2018-163 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. |
| 2018-164 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Nonsprinklered building requires access road within 150' of most remote point of building; 200' of sprinklered building |
| 2018-165 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. |
| 2018-166 | Incomplete submittal |
| 2018-167 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. Dead end access exceeding 150' requires turnaround minimum width 20'. Turn radius 30'inside 40' outside. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. |
| 2018-168 | Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No parking on road less than 26'clear width. 20' unobstructed clearance on street required at all times for CFD. |