

| Acela Number | Luesa Number |
|--------------|--|
| 2019-001 | Fire hydrant within 750' of most remote point of bldg as truck travels. Install gate per Appendix D section 503.6. See charlottefire.org for other reqmts. |
| 2019-001(c) | Fire hydrant within 750' of most remote point of bldg as truck travels. In parking lot and all driveway loops maintain continuous 24' width for CFD access. |
| 2019-002 | Incomplete submittal |
| 2019-003 | Incomplete submittal |
| 2019-004 | Incomplete submittal |
| 2019-005 | Fire hydrant within 750' of most remote point of bldg as truck travels. No parking on road less than 26' clear width. |
| 2019-006 | No comments |
| 2019-007 | Fire hydrant within 750' of most remote point of bldg as truck travels. |
| 2019-008 | Fire hydrant within 750' of most remote point of bldg as truck travels. |
| 2019-009 | Fire hydrant within 750' of most remote point of bldg as truck travels. Dead end access exceeding 150' requires turnaround minimum 20 width with turn radius 30' |
| 2019-010 | Incomplete submittal |
| 2019-011 | Fire hydrant within 750' of most remote point of bldg as truck travels. |
| 2019-012 | Fire hydrant within 750' of most remote point of bldg as truck travels. |
| 2019-013 | No comments |
| 2019-014 | Fire hydrant within 750' of most remote point of bldg as truck travels. Access road shall be 150' of nonsprinkled bldg; 200' of sprinklered bldg |
| 2019-015 | Incomplete submittal |
| 2019-016 | Fire hydrant within 750' of most remote point of bldg as truck travels. No parking on road less than 26' clear width. |