

Acela Number	Luesa Number
2019-001	Fire hydrant within 750' of most remote point of bldg as truck travels. Install gate per Appendix D section 503.6. See charlottefire.org for other reqmts.
2019-001(c)	Fire hydrant within 750' of most remote point of bldg as truck travels. In parking lot and all driveway loops maintain continuous 24' width for CFD access.
2019-002	Incomplete submittal
2019-003	Incomplete submittal
2019-004	Incomplete submittal
2019-005	Fire hydrant within 750' of most remote point of bldg as truck travels. No parking on road less than 26' clear width.
2019-006	No comments
2019-007	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-008	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-009	Fire hydrant within 750' of most remote point of bldg as truck travels. Dead end access exceeding 150' requires turnaround minimum 20 width with turn radius 30' inside and 42' outside
2019-010	No comments at this time
2019-011	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-012	Fire hydrant within 750' of most remote point of bldg as truck travels.
2019-013	No comments
2019-014	Fire hydrant within 750' of most remote point of bldg as truck travels. Access road shall be 150' of nonsprinkled bldg; 200' of sprinklered bldg
2019-015	Incomplete submittal
2019-016	Fire hydrant within 750' of most remote point of bldg as truck travels. No parking on road less than 26' clear width.