



<b>Petition #:</b>	2019-015	<b>Review Number:</b>	1
<b>Petition Respondent:</b>	Bhavana Swayampakala	<b>Date Reviewed:</b>	2/19/2019
<b>Phone Number:</b>	704-336-4976	<b>Email Address:</b>	bhavana.swayampakala@charlottenc.gov

**Comments:**

Summary: Water and sewer service is accessible for this rezoning boundary.

Charlotte Water has accessible water system infrastructure for the rezoning boundary via existing 8-inch water distribution mains located along Greensboro Street and East Sugar Creek Road and via an existing 12-inch water distribution main located along Raleigh Street.

Charlotte Water has sanitary sewer system infrastructure accessible for the rezoning boundary via an existing 8-inch gravity sewer main located along Greensboro Street, via an existing 12-inch gravity sewer main located along East Sugar Creek Road and via existing 8-inch and 12-inch gravity sewer mains located within the rezoning boundary.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Submit application to the Capacity Assurance Program. Has direct access to water/sewer. There are several sewer mains that run through this property, no permanent structures are to be located within the easement. Max amount of cover over existing main is 10'. Depending on the required public street network, this site may need to extend public water/sewer to serve their site. Send plans to Charlotte Water for private water permitting (if applicable). Send plans to NCDEQ Mooresville Regional Office (704) 663-1699 for private sewer permitting (if applicable).

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-2854 for further information on reserving capacity up to 24 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.