



To: David Pettine, CMPC

From: Ashley Botkin - Planning, Design, and Development

Date: March 27, 2019

Rezoning Petition #: 2019-030

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: www.charlottenc.gov/ld.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson (Engineering) – Please show and label "Potential 30' Post Construction Stormwater Ordinance Stream Buffer" on the site plan and adjust construction limits to comply with buffer requirements as necessary.

The rezoning plan implies a stream/wetland delineation report may have been prepared for this site. The petitioner is advised that any stream delineation report affecting the limits of potential Post Construction Stormwater Ordinance stream buffer(s) is subject to review and approval by Charlotte Stormwater Services.

Peter Grisewood (Urban Forestry) – Site is in a wedge and will be required to provide 15% tree save area based on gross acreage. $15\% \text{ of } 30.73 \text{ acres} = 4.60 \text{ acres tree save area}$. Show tree save area and calculations on site map. Tree save area must be 30' feet minimum width. Must contain existing healthy trees.

Jay Wilson (Erosion Control) –