

| Acela Number | Luesa Number |
|--------------|--|
| 2019-017 | Fire hydrant 750' from most remote point of bldg as truck travels. 20'unobstructed clearance on street at all times for CFD access |
| 2019-018 | no comments |
| 2019-019 | Fire hydrant 750' from most remote point of bldg as truck travels |
| 2019-020 | Fire hydrant 750' from most remote point of bldg as truck travels. 20'unobstructed clearance on street at all times for CFD access |
| 2019-021 | Fire hydrant 750' from most remote point of bldg as truck travels. Dead end access exceeding 150' requires turnaround minimum 20' width with turn radius 30'inside and 42' outside |
| 2019-022 | Fire hydrant 750' from most remote point of bldg as truck travels. All weather driving surface capable of sustaining 80,000 lbs |
| 2019-023 | Fire hydrant 750' from most remote point of bldg as truck travels. 20'unobstructed clearance on street at all times for CFD access. Dead end access exceeding 150' requires turnaround minimum 20' width with turn |
| 2019-024 | Fire hydrant 750' from most remote point of bldg as truck travels. |
| 2019-025 | Fire hydrant 750' from most remote point of bldg as truck travels. 20'unobstructed clearance on street at all times for CFD access. No on street parking on road less than 26' clear width. |
| 2019-026 | Fire hydrant 750' from most remote point of bldg as truck travels. 20'unobstructed clearance on street at all times for CFD access. |
| 2019-027 | Fire hydrant 750' from most remote point of bldg as truck travels |
| 2019-028 | Fire hydrant 750' from most remote point of bldg as truck travels. 20'unobstructed clearance on street at all times for CFD access. Dead end access exceeding 150' requires turnaround minimum 20' width with turn |
| 2019-029 | Fire hydrant 750' from most remote point of bldg as truck travels |
| 2019-030 | Fire hydrant 750' from most remote point of bldg as truck travels. See Section D106. IFC 2018 for access requirements. |
| 2019-031 | Fire hydrant 750' from most remote point of bldg as truck travels. No on street parking on road less than 26' clear width. |
| 2019-032 | Fire hydrant 750' from most remote point of bldg as truck travels. |