

2018-117 1- Fire hydrant to be within 750' of most remote point of bldg as fire truck travels. No on street parking on road less than 26' clear width. 2- Turn radius 30' inside and 42' outside.

2019-030 Fire hydrant 750' from most remote point of bldg as truck travels. See Section D106. IFC 2018 for access requirements. All access gates shall be a min. 40' away from drive so fire apparatus can pull off street.

2019-032 Proposed secondary emergency access shall be a min. 20' unobstructed clear width and shall be capable of supporting 80,000 pounds. Access gate shall be a min. 40' away from access road so fire apparatus can pull off street onto property.

2019-036 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-049 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-071 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-078 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-084 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-090 NO CHANGES TO PREVIOUS REVIEW COMMENTS

2019-100 NO CHANGES TO PREVIOUS REVIEW COMMENTS