

Acela Number	Luesa Number
2019-033	Fire hydrant shall be 750' from most remote point of bldg as truck travels
2019-034	Fire hydrant shall be 750' from most remote point of bldg as truck travels
2019-035	Fire hydrant shall be 750' from most remote point of bldg as truck travels
2019-036	Fire hydrant shall be 750' from most remote point of bldg as truck travels
2019-037	Fire hydrant shall be 750' from most remote point of bldg as truck travels
2019-038	Ordinance change no comments
2019-039	Fire hydrant shall be 750' from most remote point of bldg as truck travels. 20'unobstructed clearance required on street at all times for CFD access
2019-040	Fire hydrant shall be 750' from most remote point of bldg as truck travels. Access road within 150' non sprinklered bldg; 200' sprinklered bldg
2019-041	No comments
2019-042	Fire hydrant shall be 750' from most remote point of bldg as truck travels.
2019-043	Fire hydrant shall be 750' from most remote point of bldg as truck travels. 20'unobstructed clearance required on street at all times for CFD access
2019-044	Fire hydrant shall be 750' from most remote point of bldg as truck travels. See charlottefire.org for other comments
2019-045	Fire hydrant shall be 750' from most remote point of bldg as truck travels. 20'unobstructed clearance required on street at all times for CFD access
2019-046	Fire hydrant shall be 750' from most remote point of bldg as truck travels. 20'unobstructed clearance required on street at all times for CFD access
2019-047	Fire hydrant shall be 750' from most remote point of bldg as truck travels.
2019-048	Fire hydrant shall be 750' from most remote point of bldg as truck travels. 20'unobstructed clearance required on street at all times for CFD access